From: "Justin Keogh" <justin.keogh@gmail.com>
To: wtc@nist.gov
Subject: WTC7 Public Comment

Name: Justin Keogh
Affiliation:
Contact: Phone number or e-mail address where you can be contacted in case of questions.
520-265-0034
Report Number: NCSTAR 1-9
Page Number: 595
Paragraph/Sentence: Paragraph 3

Comment: The draft states: "Given the complexity of the modeled behavior, the global collapse analyses matched the observed behavior reasonably well. The global collapse analysis confirmed the leading collapse hypothesis, which was based on the available evidence."

Reason for Comment: The global collapse models to not resemble the video evidence "reasonably well".

Suggestion for Revision: The global collapse analysis shows large deformations in the building superstructure which were not observed in the video evidence. All videos of WTC7 collapsing show the curtain wall stays generally flat during the collapse. Since the window frames were attached to the trusses, interior deformations of the building's load bearing elements would be visible as deflections in the curtain wall.